



CITY 2006133946



NOV 27 2006 11:48 P 11

Received - DIANE L. BATTIATO
Register of Deeds, Douglas County, NE
11/27/2006 11:48:44.22



2006133946

**THIS PAGE INCLUDED FOR INDEXING
PAGE DOWN FOR BALANCE OF INSTRUMENT**


Cities
11/2
B

FEE None FB 03-30760
BKP _____ C/O _____ COMP MB
DEL _____ SCAN _____ FV _____

Temp. 12.4.01

CITY OF OMAHA
PLANNING DEPT.
1819 Farnam St., Rm.
Omaha, NE 68183

1003



City of Omaha
Mike Fahey, Mayor

CODE ENFORCEMENT

NOTICE OF VIOLATION

October 31, 2006

Planning Department

Omaha/Douglas Civic Center
1819 Farnam Street, Suite 1003
Omaha, Nebraska 68183
(402) 444-5150
Telefax (402) 546-0714

Steven N. Jensen, AICP
Director

Native Omahans Club Inc.
PO Box 11561
Omaha, NE 68111

Legal Description: All Lots 15 & 16, Block 5, Plainview
Addition

This notice concerns the Property at: **3819 N 024 ST Commercial building Exterior.**

The Property is in violation of the Omaha Municipal Code. The violations currently known to exist on this Property are listed in the attached Violations List.

You are ordered to repair or cure the said violations by December 30, 2006. A follow-up inspection, to determine whether the violations have been repaired or cured and whether the Property can thereby be released, will be scheduled on or shortly after that date, or sooner if you so request.

This vacant Property is declared to be unsafe, unfit for human occupancy, or unlawful, because of the violations so designated in the attached Violations List. You are ordered to close the Property and to take measures necessary to prevent occupancy of it within 60 days. Occupancy of the property is prohibited. Of course, if all violations making this property unsafe, unfit or unlawful are repaired or cured by the above date, the property can then be opened and occupied.

While the necessity of City permits to conduct the necessary work will depend on the method of repair chosen by the Property owner, it presently appears that the following types of permits will have to be obtained from the City to perform the necessary work: **Building Electrical,**

Any person directly affected by this notice may appeal to the Omaha Building Board of Review by filing a written appeal application form and \$30.00 filing fee with the office of the City Permits and Inspections Division, Omaha/Douglas Civic Center, 1819 Farnam Street, Suite 1100, Omaha, Nebraska, within 20 days of the date of this notice (add an additional three business days if this notice was sent by regular mail). The appeal application shall state all grounds for objection to this notice.

If you desire clarification of this notice or of any of the violations listed, please call the undersigned between the hours of 8:00 a.m. and 9:30 a.m. and arrangements will be made to assist you.

Sincerely,

Kurt Holmstrom
Code Inspector, 444-7728

Kevin J. Denker
Chief Code Inspector

C: First Natl Bank of Omaha, 1620 Dodge St 68102
Burton Plumbing Services, Inc, 8115 "H" St, 68127

**The City of Omaha Planning Department
Housing Division
Permits and Code Requirements
for property address: 3819 N 024 ST
Structure Type: Commercial building-Exterior
October 31, 2006**

The following permits are required for the primary structure:

A Building permit is required for the amount of \$4,000.00. Note: The fee charged for a Building permit is based on the total amount of estimated labor and material costs.

<u>Y</u> General Repair	<u>Y</u> Window Replacement	Interior Inspection.
Fire	<u>Y</u> Soffits, Gutters, etc.	Requested for the following reason(s) :
<u>Y</u> Reroof	Kitchen Remodel	
Remove Existing Roof	Bath Remodel	
Reside	Plans required	
Remove existing siding	Fence	
Basement Finish	Decks/Porches	
Retaining Wall	Fire Escape	

Separate Permits required for the following:

Y Electrical Plumbing Mechanical Wreck

Special Code Requirements:

Electrical Requirements -

Under 121-142. Chapter 44. Bring electrical service up to code. A licensed, bonded, electrical contractor is required to make repairs. A City of Omaha electrical permit and an inspection by the City Electrical Inspector is required for conformance.

Violations List

October 31, 2006

Native Omahans Club Inc.
PO Box 11561
Omaha, NE 68111

Re: 3819 N 024 ST
Inspected by: Kurt Holmstrom
Structure Type: Commercial building

Violations and corrective action:

Owner Violation List items

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u> <u>Repaired</u>
<p>043-101. Generally. All construction or work for which a permit is required shall be subject to inspection by the building official and all such construction or work shall remain accessible and exposed for inspection purposes until approved by the building official. In addition, certain types of construction shall have special inspection as specified in the building code as adopted by this jurisdiction.</p> <p>Approval as a result of an inspection shall not be construed to be an approval of a violation of the provisions of the building code, this Code or other ordinances of the jurisdiction. Inspections presuming to give authority to violate or cancel the provisions of the building code, this Code or other ordinances of the jurisdiction shall not be valid.</p> <p>It shall be the duty of the permit applicant to cause the work to remain accessible and exposed for inspection purposes. Neither the building official nor the jurisdiction shall be liable for expense entailed in the removal or replacement of any material required to allow inspection.</p> <p>A survey of the lot may be required by the building official to verify that the structure is located in accordance with the approved plans. (Ord. No 33582, SS 1(43-101), 6-27-95)</p>	<p>Building Exterior. Construction work shall remain accessible & exposed for inspections until approved.</p>	
<p>043-71. Required. Except as specified in section 43-72 of this Code, no building or structure regulated by this Code shall be erected, constructed, enlarged, altered, repaired, moved, improved, removed, converted or demolished unless a separate permit for each building or structure has first been obtained from the building official. (Ord. No. 33582 SS 1(43-71), 6-27-95)</p>	<p>Building Exterior. General permits are required.</p>	

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u>	<u>Repaired</u>
044-121. Permit required.. Before proceeding to install, alter, repair, relocate, affix or suspend any electrical wiring, or to install or connect any equipment or apparatus which requires electrical wiring to be installed, affixed or suspended to make the same operable, for either interior or exterior wiring, a permit shall be obtained by an electrical contractor or a master electrician from the electrical official at the permits and inspections division.	Building Exterior. All electrical repairs must be made by a electrical contractor, licensed and bonded by the City of Omaha & requires permits and inspections.		Yes
048-12 a. Maintenance. Equipment, systems, devices and safeguards required by this code or a previous regulation or code under which the structure or premises was constructed, altered or repaired shall be maintained in good working order. The requirements of this code are not intended to provide the basis for removal or abrogation of fire protection and safety systems and devices in existing structures. Except as otherwise specified herein, the owner or the owner's designated agent shall be responsible for the maintenance of buildings, structures and premises.	Building Exterior. Owner.		
048-12 e. Maintenance. Mechanical and plumbing systems, both existing and new, and parts thereof shall be maintained in proper operating condition in accordance with the original design and in a safe and sanitary condition. Devices or safeguards required by an applicable code shall be maintained in compliance with the code edition under which installed.	Building Exterior. Owner.		
048-13. Application of other codes. Repairs, additions or alterations to a structure, or changes of occupancy, shall be done in accordance with the procedures and provisions of the City's Building Code, Plumbing Code, Mechanical Code, Fuel Gas Code, Fire Code and Electrical Code, all as defined in this code. Nothing in this code shall be construed to cancel, modify or set aside any provisions of Chapter 55 of the Omaha Municipal Code.	Building Exterior. Owner.		
048-13. Application of other codes. Repairs, additions or alterations to a structure, or changes of occupancy, shall be done in accordance with the procedures and provisions of the City's Building Code, Plumbing Code, Mechanical Code, Fuel Gas Code, Fire Code and Electrical Code, all as defined in this code. Nothing in this code shall be construed to cancel, modify or set aside any provisions of Chapter 55 of the Omaha Municipal Code.	Building Exterior. All city codes apply.		
048-15. Workmanship. Repairs, maintenance work, alterations or installations which are caused directly or indirectly by the enforcement of this code shall be executed and installed in a workmanlike manner and installed in accordance with the manufacturer's installation instructions.	Building Exterior. All repairs, alterations, maintenance work & installations shall be made in a workmanlike manner, and in accordance with manufacturer's installation instructions.		

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u>	<u>Unfit Repaired</u>
048-53. Prosecution of violation. Any person failing to comply with a notice of violation or order served in accordance with this code shall be deemed guilty of a misdemeanor, as provided in Section 1-10 of the Omaha Municipal Code. If the notice of violation is not complied with, the code official may institute the appropriate proceeding at law or in equity to restrain, correct or abate such violation, or to require the removal or termination of the unlawful occupancy of the structure in violation of the provisions of this code or of the order or direction made pursuant thereto.	Building Exterior. Any person failing to comply with a notice shall be prosecuted.		
048-65. Transfer of ownership. If the ownership of a property subject to a pending notice or order under this code is to be transferred, the transferring owner shall report to the city housing division the impending transfer of the property and the name and address of the transferee, at least seven (7) days prior to the transfer.	Building Exterior. Inspector must be noticed of pending transfer of ownership seven (7) days prior to transfer.		
048-71a. General. When a structure or equipment is found by the code official to be unsafe, or when a structure is found unfit for human occupancy, or is found unlawful, such structure shall be declared as such by notice pursuant to the provisions of this code.	Building Exterior. Structure report given for back deck system.	Yes	
a. Unsafe Structure. An unsafe structure is one that is found to be dangerous to the life, health, property or safety of the public or the occupants of the structure by not providing minimum safeguards to protect or warn occupants in the event of fire, or because such structure contains unsafe equipment or is so damaged, decayed, dilapidated, structurally unsafe, or of such faulty construction or unstable foundation that partial or complete collapse is possible.			
048-71b. General. When a structure or equipment is found by the code official to be unsafe, or when a structure is found unfit for human occupancy, or is found unlawful, such structure shall be declared as such by notice pursuant to the provisions of this code.	Building Exterior. Electrical system is deteriorated.	Yes	
b) Unsafe equipment. Unsafe equipment includes any boiler, heating equipment, elevator, moving stairway, electrical wiring or device, flammable liquid containers or other equipment on the premises or within the structure which is in such disrepair or condition that such equipment is a hazard to life, health, property or safety of the public or occupants of the premises or structure.			
048-74. Placarding. Upon failure of the owner or person responsible to comply with the notice provisions within the time given, the code official shall post on the premises or on defective equipment a placard reading "Danger - Closed" or similar language, and a statement of the penalties provided for occupying the premises, operating the equipment or removing the placard.	Building Exterior. Upon failure to comply within the time given, structure shall be placarded.		
048-75. Prohibited occupancy. It shall be unlawful for any person to occupy a placarded premises or to operate placarded equipment, and for any owner or any person responsible for the premises to let anyone occupy a placarded premises or operate placarded equipment. Such persons shall be liable for the penalties provided by this Code.	Building Exterior. Upon failure to comply within the time given, structure shall be vacated.		

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u>	<u>Repaired</u>
048-81. Imminent danger. When, in the opinion of the code official, there is imminent danger of failure or collapse of a building or structure which endangers life, or when any structure or part of a structure has fallen and life is endangered by the occupation of the structure, or when there is actual or potential danger to the building occupants or those in the proximity of any structure because of explosives, explosive fumes or vapors or the presence of toxic fumes, gases or materials, or operation of defective or dangerous equipment, the code official is hereby authorized and empowered to order and require the occupants to vacate the premises forthwith. The code official shall cause to be posted at each entrance to such structure a notice reading as follows: "This Structure Is Unsafe and Its Occupancy Has Been Prohibited By The Code Official", or similar language. It shall be unlawful for any person to enter such structure except for the purpose of securing the structure, making the required repairs, removing the hazardous condition or of demolishing the same.	Building Exterior. Back deck deteriorated.		Yes
301.2. Responsibility. The owner of the premises shall maintain the structures and exterior property in compliance with these requirements, except as otherwise provided for in this code. A person shall not occupy as owner-occupant or permit another person to occupy premises which are not in a sanitary and safe condition and which do not comply with the requirements of this chapter. Occupants of a dwelling unit are responsible for keeping in a clean, sanitary and safe condition that part of the dwelling unit or premises which they occupy and control.	Building Exterior. Entire Structure.	Owner.	
302.1. Sanitation. All exterior property and premises shall be maintained in a clean, safe and sanitary condition. The occupant shall keep that part of the exterior property which such occupant occupies or controls in a clean and sanitary condition.	Building Exterior. Litter and/or debris on exterior property and premises.		
302.3. Sidewalks and driveways. All sidewalks, walkways, stairs, driveways, parking spaces and similar areas shall be kept in a proper state of repair, and maintained free from hazardous conditions.	Building Exterior. Trip hazard at sidewalks front of structure.		Yes
303.1. General. The exterior of a structure shall be maintained in good repair, structurally sound and sanitary so as not to pose a threat to the public health, safety or welfare.	Building Exterior.	Owner.	
303.10. Stairways, decks, porches and balconies. Every exterior stairway, deck, porch and balcony, and all appurtenances attached thereto, shall be maintained structurally sound, in good repair, with proper anchorage and capable of supporting the imposed loads.	Building Exterior. Deteriorated deck and stairs at back of structure.		
303.10. Stairways, decks, porches and balconies. Every exterior stairway, deck, porch and balcony, and all appurtenances attached thereto, shall be maintained structurally sound, in good repair, with proper anchorage and capable of supporting the imposed loads.	Building Exterior. Deteriorated guardrails.		Yes
303.10. Stairways, decks, porches and balconies. Every exterior stairway, deck, porch and balcony, and all appurtenances attached thereto, shall be maintained structurally sound, in good repair, with proper anchorage and capable of supporting the imposed loads.	Building Exterior. Deteriorated deck(s).		

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u>	<u>Repaired</u>
303.12 Handrails and guards. Every handrail and guard shall be firmly fastened and capable of supporting normally imposed loads and shall be maintained in good condition.	Building Exterior. Deteriorated rails on back porch.		Yes
303.12. Handrails and guards. Every handrail and guard shall be firmly fastened and capable of supporting normally imposed loads and shall be maintained in good condition.	Building Exterior. Loose handrails and guards on deck(s), steps, and /or porch.		
303.13. Window, skylight and door frames. Every window, skylight, door and frame shall be kept in sound condition, good repair and weather tight.	Building Exterior. Deteriorated entry door.		
303.13. Window, skylight and door frames. Every window, skylight, door and frame shall be kept in sound condition, good repair and weather tight.	Building Exterior. Deteriorated storm windows and missing inserts on all sides.		
303.13. Window, skylight and door frames. Every window, skylight, door and frame shall be kept in sound condition, good repair and weather tight.	Building Exterior. Deteriorated window sash, jambs, sills, and trim throughout.		
303.13. Window, skylight and door frames. Every window, skylight, door and frame shall be kept in sound condition, good repair and weather tight.	Building Exterior. Loose and missing window ropes, sash supports and locks.		
303.13.1. Glazing. All glazing materials shall be maintained free from cracks and holes.	Building Exterior. Loose and missing window glazing putty at windows on all sides.		
303.13.2. Openable windows. Every window, other than a fixed window, shall be easily openable and capable of being held in position by window hardware.	Building Exterior. Broken and missing sash ropes throughout.		Yes
303.13.2. Openable windows. Every window, other than a fixed window, shall be easily openable and capable of being held in position by window hardware.	Building Exterior. Openable window sash nailed shut, stops missing, broken window locks, .		Yes
303.15. Doors. All exterior doors, door assemblies and hardware shall be maintained in good condition. Locks at all entrances to dwelling units, rooming units and guest rooms shall tightly secure the door. Locks on means of egress doors shall be in accordance with Section 702.3.	Building Exterior. Deteriorated and/or missing storm doors at all entries.		
303.15. Doors. All exterior doors, door assemblies and hardware shall be maintained in good condition. Locks at all entrances to dwelling units, rooming units and guest rooms shall tightly secure the door. Locks on means of egress doors shall be in accordance with Section 702.3.	Building Exterior. Deteriorated front door and hardware of all entrances to apartments.		
303.15. Doors. All exterior doors, door assemblies and hardware shall be maintained in good condition. Locks at all entrances to dwelling units, rooming units and guest rooms shall tightly secure the door. Locks on means of egress doors shall be in accordance with Section 702.3.	Building Exterior. Doors are not weather tight.		

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation Repaired</u>
<p>303.15. Doors. All exterior doors, door assemblies and hardware shall be maintained in good condition. Locks at all entrances to dwelling units, rooming units and guest rooms shall tightly secure the door. Locks on means of egress doors shall be in accordance with Section 702.3.</p>	<p>Building Exterior. Missing threshold at front door(s).</p>	
<p>303.2. Protective treatment. All exterior surfaces, including but not limited to, doors, door and window frames, cornices, porches, trim, balconies, decks and fences shall be maintained in good condition. Exterior wood surfaces, other than decay-resistant woods, shall be protected from the elements and decay by painting or other protective covering or treatment. Peeling, flaking and chipped paint shall be eliminated and surfaces repainted. All siding and masonry joints, as well as those between the building envelope and the perimeter of windows, doors and skylights shall be maintained, weather resistant and water-tight. All metal surfaces subject to rust or corrosion shall be coated to inhibit such rust and corrosion and all surfaces with rust or corrosion shall be stabilized and coated to inhibit future rust and corrosion. Oxidation stains shall be removed from exterior surfaces. Surfaces designed for stabilization by oxidation are exempt from this requirement.</p>	<p>Building Exterior. Peeling paint on exterior wood surfaces.</p>	
<p>303.2. Protective treatment. All exterior surfaces, including but not limited to, doors, door and window frames, cornices, porches, trim, balconies, decks and fences shall be maintained in good condition. Exterior wood surfaces, other than decay-resistant woods, shall be protected from the elements and decay by painting or other protective covering or treatment. Peeling, flaking and chipped paint shall be eliminated and surfaces repainted. All siding and masonry joints, as well as those between the building envelope and the perimeter of windows, doors and skylights shall be maintained, weather resistant and water-tight. All metal surfaces subject to rust or corrosion shall be coated to inhibit such rust and corrosion and all surfaces with rust or corrosion shall be stabilized and coated to inhibit future rust and corrosion. Oxidation stains shall be removed from exterior surfaces. Surfaces designed for stabilization by oxidation are exempt from this requirement.</p>	<p>Building Exterior. Peeling/missing paint on eaves, sashes, jambs, and trim.</p>	
<p>303.2. Protective treatment. All exterior surfaces, including but not limited to, doors, door and window frames, cornices, porches, trim, balconies, decks and fences shall be maintained in good condition. Exterior wood surfaces, other than decay-resistant woods, shall be protected from the elements and decay by painting or other protective covering or treatment. Peeling, flaking and chipped paint shall be eliminated and surfaces repainted. All siding and masonry joints, as well as those between the building envelope and the perimeter of windows, doors and skylights shall be maintained, weather resistant and water-tight. All metal surfaces subject to rust or corrosion shall be coated to inhibit such rust and corrosion and all surfaces with rust or corrosion shall be stabilized and coated to inhibit future rust and corrosion. Oxidation stains shall be removed from exterior surfaces. Surfaces designed for stabilization by oxidation are exempt from this requirement.</p>	<p>Building Exterior. Siding is not weather tight.</p>	

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u>	<u>Repaired</u>
303.7. Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that admit rain. Roof drainage shall be adequate to prevent dampness or deterioration in the walls or interior portion of the structure. Roof drains, gutters and downspouts shall be maintained in good repair and free from obstructions. Roof water shall not be discharged in a manner that creates a public nuisance.	Building Exterior. Deteriorated fascia back of structure.		
303.7. Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that admit rain. Roof drainage shall be adequate to prevent dampness or deterioration in the walls or interior portion of the structure. Roof drains, gutters and downspouts shall be maintained in good repair and free from obstructions. Roof water shall not be discharged in a manner that creates a public nuisance.	Building Exterior. Deteriorated soffits and fascia.		
303.7. Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that admit rain. Roof drainage shall be adequate to prevent dampness or deterioration in the walls or interior portion of the structure. Roof drains, gutters and downspouts shall be maintained in good repair and free from obstructions. Roof water shall not be discharged in a manner that creates a public nuisance.	Building Exterior. Improper installation of roofing materials.	Yes	
303.7. Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that admit rain. Roof drainage shall be adequate to prevent dampness or deterioration in the walls or interior portion of the structure. Roof drains, gutters and downspouts shall be maintained in good repair and free from obstructions. Roof water shall not be discharged in a manner that creates a public nuisance.	Building Exterior. Deteriorated roof covering.		
305.1. Accumulation of rubbish or garbage. All exterior property and premises, and the interior of every structure, shall be free from any accumulation of rubbish or garbage.	Building Exterior. Dwelling interior has an extensive accumulation of household items.		
501.2. Responsibility. The owner of the structure shall provide and maintain such plumbing facilities and plumbing fixtures in compliance with these requirements. A person shall not occupy as owner-occupant or permit another person to occupy any structure or premises which does not comply with the requirements of this chapter.	Building Exterior. Owner		
601.2. Responsibility. The owner of the structure shall provide and maintain mechanical and electrical facilities and equipment in compliance with these requirements. A person shall not occupy as owner-occupant or permit another person to occupy any premises which does not comply with the requirements of this chapter.	Building Exterior. Owner.		
603.1. Mechanical appliances. All mechanical appliances, fireplaces, solid fuel-burning appliances, cooking appliances and water heating appliances shall be properly installed and maintained in a safe working condition and shall be capable of performing the intended function.	Building Exterior. Furnace must be checked by a licensed, bonded contractor with the City of Omaha & requires permits and inspections.		

Code Section Violated

Location and Nature of Violation

Unsafe/Unfit
Designation Repaired

604.3. Electrical system hazards. Where it is found that the electrical system in a structure constitutes a hazard to the occupants or the structure by reason of inadequate service, improper fusing, insufficient receptacle and lighting outlets, improper wiring or installation, deterioration or damage, or for similar reasons, the code official shall require the defects to be corrected to eliminate the hazard.

Building Exterior. Exposed wiring back deck of structure Yes