



CITY 2008012960



FEB 11 2008 11:08 P 11

Cities
FEE None FB 23-32320
BKP _____ C/O _____ COMP MB
DEL _____ SCAN _____ FV _____

Received - DIANE L. BATTIATO
Register of Deeds, Douglas County, NE
2/11/2008 11:08:33.99

2008012960

**THIS PAGE INCLUDED FOR INDEXING
PAGE DOWN FOR BALANCE OF INSTRUMENT**

FEE _____ FB _____
BKP _____ C/O _____ COMP _____
DEL _____ SCAN _____ FV _____

**Return To:
City of Omaha
Planning Department
Code Enforcement
1819 Farnam St, Rm. 1003
Omaha, NE 68183**



City of Omaha
Mike Fahey, Mayor

CODE ENFORCEMENT

NOTICE OF VIOLATION

January 18, 2008

Planning Department

Omaha/Douglas Civic Center
1819 Farnam Street, Suite 1003
Omaha, Nebraska 68183
(402) 444-5150
Telefax (402) 546-0714

Steven N. Jensen, AICP
Director

John E. Schmidt
5630 South 21st Street
Omaha, NE 68107

Legal Description: S 63' of W 150' of Lot 28 & W 148' of
Lot 33, Redicks 2nd Addition

This notice concerns the Property at: **907 S 025 ST Apt. No. 9B Apartment Interior 9B.**

The Property is in violation of the Omaha Municipal Code. The violations currently known to exist on this Property are listed in the attached Violations List.

You are ordered to repair or cure the said violations by March 18, 2008. A follow-up inspection, to determine whether the violations have been repaired or cured and whether the Property can thereby be released, will be scheduled on or shortly after that date, or sooner if you so request.


This vacant Property is declared to be unsafe, unfit for human occupancy, or unlawful, because of the violations so designated in the attached Violations List. You are ordered to close the Property and to take measures necessary to prevent occupancy of it within 60 days. Occupancy of the property is prohibited. Of course, if all violations making this property unsafe, unfit or unlawful are repaired or cured by the above date, the property can then be opened and occupied.


While the necessity of City permits to conduct the necessary work will depend on the method of repair chosen by the Property owner, it presently appears that the following types of permits will have to be obtained from the City to perform the necessary work: **Building**

Any person directly affected by this notice may appeal to the Omaha Building Board of Review by filing a written appeal application form and \$30.00 filing fee with the office of the City Permits and Inspections Division, Omaha/Douglas Civic Center, 1819 Farnam Street, Suite 1100, Omaha, Nebraska, within 20 days of the date of this notice (add an additional three business days if this notice was sent by regular mail). The appeal application shall state all grounds for objection to this notice.

If you desire clarification of this notice or of any of the violations listed, please call the undersigned between the hours of 8:00 a.m. and 9:30 a.m. and arrangements will be made to assist you.

Sincerely,


Mike Johnson
Code Inspector, 402-444-5446


Kevin J. Denker
Chief Code Inspector

C:

**The City of Omaha Planning Department
Housing Division
Permits and Code Requirements**
for property address: 907 S 025 ST Apt. No. 9B
Structure Type: Apartment-Interior 9B-Apt.9B
January 18, 2008

The following permit is required for the primary structure:

A Building permit is required for the amount of \$2,000.00. Note: The fee charged for a Building permit is based on the total amount of estimated labor and material costs.

<u>Y</u> General Repair	Window Replacement	Interior Inspection.
Fire	Soffits, Gutters, etc.	Requested for the following reason(s) :
Reroof	Kitchen Remodel	
Remove Existing Roof	Bath Remodel	
Reside	Plans required	
Remove existing siding	Fence	
Basement Finish	Decks/Porches	
Retaining Wall	Fire Escape	

Separate Permits required for the following:

Electrical Plumbing Mechanical Wreck

Violations List

January 18, 2008

John E. Schmidt
5630 South 21st Street
Omaha, NE 68107

Re: 907 S 025 ST Apt. No. 9B
Inspected by: Mike Johnson
Structure Type: Apartment

Violations and corrective action:

Owner Violation List items

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u> <u>Repaired</u>
<p>043-101. Generally. All construction or work for which a permit is required shall be subject to inspection by the building official and all such construction or work shall remain accessible and exposed for inspection purposes until approved by the building official. In addition, certain types of construction shall have special inspection as specified in the building code as adopted by this jurisdiction.</p> <p>Approval as a result of an inspection shall not be construed to be an approval of a violation of the provisions of the building code, this Code or other ordinances of the jurisdiction. Inspections presuming to give authority to violate or cancel the provisions of the building code, this Code or other ordinances of the jurisdiction shall not be valid.</p> <p>It shall be the duty of the permit applicant to cause the work to remain accessible and exposed for inspection purposes. Neither the building official nor the jurisdiction shall be liable for expense entailed in the removal or replacement of any material required to allow inspection.</p> <p>A survey of the lot may be required by the building official to verify that the structure is located in accordance with the approved plans. (Ord. No 33582, SS 1(43-101), 6-27-95)</p>	<p>Apartment 9B. Construction work shall remain accessible & exposed for inspections until approved.</p>	
<p>043-71. Required. Except as specified in section 43-72 of this Code, no building or structure regulated by this Code shall be erected, constructed, enlarged, altered, repaired, moved, improved, removed, converted or demolished unless a separate permit for each building or structure has first been obtained from the building official. (Ord. No. 33582 SS 1(43-71), 6-27-95)</p>	<p>Apartment 9B. General repair permit is required before work is started.</p>	

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u> <u>Repaired</u>
043-91. Permit Fees. Fees shall be assessed in accordance with the provisions of this section. The fee for each building permit shall be as set forth in Table 43-91.	Apartment 9B. Fee shall be assessed in accordance with the provisions of this sections.	
The determination of value or valuation for the purpose of assessing the permit fee shall be made by the building official. The value to be used in computing the building permit and plan review fees shall be the total value of all construction work for which the permit is issued.		
Penalty fees: When construction begins before the permit has been issued, the applicant shall pay a penalty fee. Said fee shall be quadruple the amount of the regular fee.		
No quadruple fee penalty set forth in this chapter shall be imposed if the work is of an emergency nature where a delay in performing the work may cause a risk to life or health or will significantly increase the risk of property damage, provided a permit is applied for within 48 hours of the start of the work, in which case no penalty shall be imposed.		
043-94. Commencing work without permit. Whenever any work for which a permit is required has been commenced without first obtaining said permit, a special investigation shall be made before a permit may be issued. A penalty fee shall be assessed in accordance with table 43-91. Payment of the penalty fee shall not exempt the applicant from making any changes that may be required to bring the work into compliance with the city's building, zoning and other codes. (Ord. No 33582, SS 1(43-94), 6-27-95)	Apartment 9B. Whenever any work for which a permit is required has been commenced without first obtaining said permit a penalty fee shall be assessed.	
048-13. Application of other codes. Repairs, additions or alterations to a structure, or changes of occupancy, shall be done in accordance with the procedures and provisions of the City's Building Code, Plumbing Code, Mechanical Code, Fuel Gas Code, Fire Code and Electrical Code, all as defined in this code. Nothing in this code shall be construed to cancel, modify or set aside any provisions of Chapter 55 of the Omaha Municipal Code.	Apartment 9B. All city codes apply.	
048-15. Workmanship. Repairs, maintenance work, alterations or installations which are caused directly or indirectly by the enforcement of this code shall be executed and installed in a workmanlike manner and installed in accordance with the manufacturer's installation instructions.	Apartment 9B. All repairs, alterations, maintenance work & installations shall be made in a workmanlike manner, and in accordance with manufacturer's installation instructions.	
048-31. General. The code official shall enforce the provisions of this code.	Apartment 9B. This code will be enforced.	
048-34. Right of entry. The code official is authorized to enter the structure or premises at reasonable times to inspect subject to constitutional restrictions on unreasonable searches and seizures. If entry is refused or not obtained, the code official is authorized to pursue recourse as provided by law.	Apartment 9B. The code official is authorized to enter the structure or premises at reasonable times.	

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u> <u>Repaired</u>
048-51. Unlawful acts. It shall be unlawful for a person, firm or corporation to be in conflict with or in violations of any of the provisions of this code.	Apartment 9B. Any violation of any provision of this code is unlawful.	
048-53. Prosecution of violation. Any person failing to comply with a notice of violation or order served in accordance with this code shall be deemed guilty of a misdemeanor, as provided in Section 1-10 of the Omaha Municipal Code. If the notice of violation is not complied with, the code official may institute the appropriate proceeding at law or in equity to restrain, correct or abate such violation, or to require the removal or termination of the unlawful occupancy of the structure in violation of the provisions of this code or of the order or direction made pursuant thereto.	Apartment 9B. Any person failing to comply with a notice shall be prosecuted.	
048-54. Violation penalties. Any person who shall violate a provision of this code, or fail to comply therewith, or with any of the requirements thereof, shall be prosecuted within the limits provided by state or local laws. Each day that a violation continues after due notice has been served shall be deemed a separate offense.	Apartment 9B. Any person who violates a provision of this code shall be prosecuted within the limits provided by state or locals laws.	
048-61. Notice to owner or to person or persons responsible. Whenever the code official determines that there has been a violation of this code or has grounds to believe that a violation has occurred, notice shall be given to the owner or the person or persons responsible therefore in the manner prescribed in sections 48-62 and 48-63. Not more than one notice of violations shall be issued for the same violation. Notices for procedures declaring property unsafe or unfit for human occupancy shall also comply with Division 8.	Apartment 9B. Owner	
048-65. Transfer of ownership. If the ownership of a property subject to a pending notice or order under this code is to be transferred, the transferring owner shall report to the city housing division the impending transfer of the property and the name and address of the transferee, at least seven (7) days prior to the transfer.	Apartment 9B. Inspector must be noticed of pending transfer of ownership seven (7) days prior to transfer.	
048-71a. General. When a structure or equipment is found by the code official to be unsafe, or when a structure is found unfit for human occupancy, or is found unlawful, such structure shall be declared as such by notice pursuant to the provisions of this code.	Apartment 9B. No working smoke detectors.	Yes
a. Unsafe Structure. An unsafe structure is one that is found to be dangerous to the life, health, property or safety of the public or the occupants of the structure by not providing minimum safeguards to protect or warn occupants in the event of fire, or because such structure contains unsafe equipment or is so damaged, decayed, dilapidated, structurally unsafe, or of such faulty construction or unstable foundation that partial or complete collapse is possible.		

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u> <u>Repaired</u>
<p>048-71a. General. When a structure or equipment is found by the code official to be unsafe, or when a structure is found unfit for human occupancy, or is found unlawful, such structure shall be declared as such by notice pursuant to the provisions of this code.</p>	<p>Apartment 9B. Open hole and penetrations through floors and or walls and or ceilings.</p>	<p>Yes</p>
<p>a. Unsafe Structure. An unsafe structure is one that is found to be dangerous to the life, health, property or safety of the public or the occupants of the structure by not providing minimum safeguards to protect or warn occupants in the event of fire, or because such structure contains unsafe equipment or is so damaged, decayed, dilapidated, structurally unsafe, or of such faulty construction or unstable foundation that partial or complete collapse is possible.</p>		
<p>048-71a. General. When a structure or equipment is found by the code official to be unsafe, or when a structure is found unfit for human occupancy, or is found unlawful, such structure shall be declared as such by notice pursuant to the provisions of this code.</p>	<p>Apartment 9B. Deteriorated kitchen cabinets and counter tops.</p>	<p>Yes</p>
<p>a. Unsafe Structure. An unsafe structure is one that is found to be dangerous to the life, health, property or safety of the public or the occupants of the structure by not providing minimum safeguards to protect or warn occupants in the event of fire, or because such structure contains unsafe equipment or is so damaged, decayed, dilapidated, structurally unsafe, or of such faulty construction or unstable foundation that partial or complete collapse is possible.</p>		
<p>048-71a. General. When a structure or equipment is found by the code official to be unsafe, or when a structure is found unfit for human occupancy, or is found unlawful, such structure shall be declared as such by notice pursuant to the provisions of this code.</p>	<p>Apartment 9B. Plexiglass used as window glazing.</p>	<p>Yes</p>
<p>a. Unsafe Structure. An unsafe structure is one that is found to be dangerous to the life, health, property or safety of the public or the occupants of the structure by not providing minimum safeguards to protect or warn occupants in the event of fire, or because such structure contains unsafe equipment or is so damaged, decayed, dilapidated, structurally unsafe, or of such faulty construction or unstable foundation that partial or complete collapse is possible.</p>		
<p>048-72. Closing of vacant structures. If the structure is vacant and unfit for human habitation and occupancy, and is not in danger of structural collapse, the code official is authorized to post a closure placard on the premises and order the structure closed up so as not to be an attractive nuisance. Upon failure of the owner to close up the premises within the time specified in the order, the code official shall cause the premises to be closed and secured through any available public agency or by contract or arrangement by private persons and the cost thereof shall be charged against the real estate upon which the structure is located and shall be a lien upon such real estate and may be collected by any other legal resource.</p>	<p>Apartment 9B. Apartment is to remain vacant until all repairs and inspections are final.</p>	

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u>	<u>Repaired</u>
048-74. Placarding. Upon failure of the owner or person responsible to comply with the notice provisions within the time given, the code official shall post on the premises or on defective equipment a placard reading "Danger - Closed" or similar language, and a statement of the penalties provided for occupying the premises, operating the equipment or removing the placard.	Apartment 9B. Upon failure to comply within the time given, structure shall be placarded.		
048-75. Prohibited occupancy. It shall be unlawful for any person to occupy a placarded premises or to operate placarded equipment, and for any owner or any person responsible for the premises to let anyone occupy a placarded premises or operate placarded equipment. Such persons shall be liable for the penalties provided by this Code.	Apartment 9B. Occupancy is prohibited until all required permits have been obtained, all repairs have been completed, all final inspections have been completed.		
049-300. Required. It shall be unlawful for any person to begin any job of plumbing until a license holder has secured from the permits and inspections division a permit to do such work; provided that no permit will be required for minor repair work as defined in sections 49-400 and 49-303.	Apartment 9B. All plumbing repairs must be made by a plumbing contractor, licensed and bonded by the City of Omaha. Appropriate plumbing permits and inspections are required.	Yes	
301.2. Responsibility. The owner of the premises shall maintain the structures and exterior property in compliance with these requirements, except as otherwise provided for in this code. A person shall not occupy as owner-occupant or permit another person to occupy premises which are not in a sanitary and safe condition and which do not comply with the requirements of this chapter. Occupants of a dwelling unit are responsible for keeping in a clean, sanitary and safe condition that part of the dwelling unit or premises which they occupy and control.	Apartment 9B. Owner. Apartment is unsafe because of violations.	Yes	
301.3. Vacant structures and land. All vacant structures and premises thereof or vacant land shall be maintained in a clean, safe, secure and sanitary condition as provided herein so as not to cause a blighting problem or adversely affect the public health or safety.	Apartment 9B. Owner. apartment is vacant and must be maintained in a clean, safe, secure, and sanitary condition.	Yes	
303.13. Window, skylight and door frames. Every window, skylight, door and frame shall be kept in sound condition, good repair and weather tight.	Apartment 9B. Plexiglass being used as window glazing.	Yes	
303.13.1. Glazing. All glazing materials shall be maintained free from cracks and holes.	Apartment 9B. Plexiglass being used as window glazing.	Yes	
304.1. General. The interior of a structure and equipment therein shall be maintained in good repair, structurally sound and in a sanitary condition. Occupants shall keep that part of the structure which they occupy or control in a clean and sanitary condition. Every owner of a structure containing a rooming house, a hotel, a dormitory, two or more dwelling units or two or more nonresidential occupancies, shall maintain, in a clean and sanitary condition, the shared or public areas of the structure and exterior property.	Apartment 9B. Owner. Unsanitary throughout apartment. Water damage. Soiled deteriorated floors, walls, ceilings, cabinets, doors.	Yes	

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u>	<u>Repaired</u>
304.3. Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking, or abraded paint shall be repaired, removed, or covered. Cracked or loose plaster, decayed wood, and other defective surface conditions shall be corrected.	Apartment 9B. Water damaged ceiling(s)	Yes	
304.3. Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking, or abraded paint shall be repaired, removed, or covered. Cracked or loose plaster, decayed wood, and other defective surface conditions shall be corrected.	Apartment 9B. Deteriorated, abraded, broken kitchen cabinet(s)	Yes	
304.3. Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking, or abraded paint shall be repaired, removed, or covered. Cracked or loose plaster, decayed wood, and other defective surface conditions shall be corrected.	Apartment 9B. Unsanitary throughout.	Yes	
304.3. Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking, or abraded paint shall be repaired, removed, or covered. Cracked or loose plaster, decayed wood, and other defective surface conditions shall be corrected.	Apartment 9B. Counter top is rotted at kitchen sink	Yes	
304.3. Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking, or abraded paint shall be repaired, removed, or covered. Cracked or loose plaster, decayed wood, and other defective surface conditions shall be corrected.	Apartment 9B. unfinished and abraded doors.	Yes	
304.3. Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking, or abraded paint shall be repaired, removed, or covered. Cracked or loose plaster, decayed wood, and other defective surface conditions shall be corrected.	Apartment 9B. Deteriorated kitchen floor.	Yes	
304.3. Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking, or abraded paint shall be repaired, removed, or covered. Cracked or loose plaster, decayed wood, and other defective surface conditions shall be corrected.	Apartment 9B. Bathroom floor is soft, sub flooring is rotted.	Yes	
304.3. Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking, or abraded paint shall be repaired, removed, or covered. Cracked or loose plaster, decayed wood, and other defective surface conditions shall be corrected.	Apartment 9B. Ducts are dirty and need to be cleaned. Receipt from duct cleaning company is to be given to inspector.	Yes	
304.3. Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking, or abraded paint shall be repaired, removed, or covered. Cracked or loose plaster, decayed wood, and other defective surface conditions shall be corrected.	Apartment 9B. Abraded finish on bathtub.	Yes	

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u>	<u>Repaired</u>
304.3. Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking, or abraded paint shall be repaired, removed, or covered. Cracked or loose plaster, decayed wood, and other defective surface conditions shall be corrected.	Apartment 9B. Deteriorated and abraded entry door.	Yes	
304.4. Stairs and walking surfaces. Every stair, ramp, landing, balcony, porch, deck or other walking surface shall be maintained in sound condition and good repair.	Apartment 9B. Bathroom floor is soft, sub flooring is rotted.	Yes	
304.4. Stairs and walking surfaces. Every stair, ramp, landing, balcony, porch, deck or other walking surface shall be maintained in sound condition and good repair.	Apartment 9B. Deteriorated kitchen floor.	Yes	
304.6. Interior doors. Every interior door shall fit reasonably well within its frame and shall be capable of being opened and closed by being properly and securely attached to jambs, headers or tracks as intended by the manufacturer of the attachment hardware.	Apartment 9B. Deteriorated, abraded apartment entry door and hardware.		Yes
501.2. Responsibility. The owner of the structure shall provide and maintain such plumbing facilities and plumbing fixtures in compliance with these requirements. A person shall not occupy as owner-occupant or permit another person to occupy any structure or premises which does not comply with the requirements of this chapter.	Apartment 9B. Owner	Yes	
504.1. General. All plumbing fixtures shall be properly installed and maintained in working order, and shall be kept free from obstructions, leaks and defects and be capable of performing the function for which such plumbing fixtures are designed. All plumbing fixtures shall be maintained in a safe, sanitary and functional condition.	Apartment 9B. Non code PVC piping.	Yes	
504.3. Plumbing system hazards. Where it is found that a plumbing system in a structure constitutes a hazard to the occupants or the structure by reason of inadequate service, inadequate venting, cross connection, back siphonage, improper installation, deterioration or damage or for similar reasons, the code official shall require the defects to be corrected to eliminate the hazard.	Apartment 9B. Abraded bathtub finish.	Yes	
504.3. Plumbing system hazards. Where it is found that a plumbing system in a structure constitutes a hazard to the occupants or the structure by reason of inadequate service, inadequate venting, cross connection, back siphonage, improper installation, deterioration or damage or for similar reasons, the code official shall require the defects to be corrected to eliminate the hazard.	Apartment 9B. Non-code PVC plastic plumbing.	Yes	
601.2. Responsibility. The owner of the structure shall provide and maintain mechanical and electrical facilities and equipment in compliance with these requirements. A person shall not occupy as owner-occupant or permit another person to occupy any premises which does not comply with the requirements of this chapter.	Apartment 9B. A licensed, bonded electrical contractor with the City of Omaha must check electrical system and the report given to the inspector.	Yes	

<u>Code Section Violated</u>	<u>Location and Nature of Violation</u>	<u>Unsafe/Unfit Designation</u>	<u>Repaired</u>
603.1. Mechanical appliances. All mechanical appliances, fireplaces, solid fuel-burning appliances, cooking appliances and water heating appliances shall be properly installed and maintained in a safe working condition and shall be capable of performing the intended function.	Apartment 9B. Ducts are dirty and need to be cleaned. Receipt from duct cleaning company is to be given to inspector.	Yes	
605.1. Installation. All electrical equipment, wiring and appliances shall be properly installed and maintained in a safe and approved manner.	Apartment 9B. Recessed light missing cover ring.	Yes	
605.1. Installation. All electrical equipment, wiring and appliances shall be properly installed and maintained in a safe and approved manner.	Apartment 9B. Kitchen range hood exhaust fan not working.	Yes	
701.2. Responsibility. The owner of the premises shall provide and maintain such fire safety facilities and equipment in compliance with these requirements. A person shall not occupy as owner-occupant or permit another person to occupy any premises that do not comply with the requirements of this chapter.	Apartment 9B. Owner.	Yes	
704.1. Smoke detectors. Existing Group R occupancies not already provided with single-station smoke alarms shall be provided with approved single-station smoke alarms.	Apartment 9B. Missing and non working smoke detectors throughout.	Yes	